



**Informal Interpretation Report
Number 7024**



Date July 03, 2012

Edition 2010

Section 502.2.2.1.1

Question:

Is it the intent of the above section that the insulation required for the exterior wall construction does not include insulation installed in the cores of masonry units?

Answer

NOTE: THE REFERENCED CODE SECTION IS LOCATED IN THE FLORIDA ENERGY CONSERVATION VOLUME OF THE FLORIDA BUILDING CODE...

ANSWER: Yes, that is what the last sentence of section 502.2.2.1.1 says.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.