



**Informal Interpretation Report
Number 7026**



Date July 03, 2012

Edition 2010

Section 1604.5

Question:

Is it the intent of table 1604.5 to classify any building containing a fire pump as a risk category IV building?

Answer

As a minimum, the pump room is to be integrated into the same Risk Category as the Occupancy Category it serves.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.