



**Informal Interpretation Report
Number 7031**



Date July 13, 2012

Edition 2010

Section R301.2.1

Question:

Is it the intent of this code code not to allow for Risk Caterory 1 wind maps to be used on all buildings that fall under the provisions of the Residential Code

Answer

It appears that the construction regulated by the FBCR will probably be the most likely to see Risk Category I structures. R301.1.1 and R301,1.2 provides a code trail to Section 1604.5 and Table 1604.5 of the FBCB for such structures

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.