



**Informal Interpretation Report
Number 7036**



Date July 13, 2012

Edition 2010

Section 310.1

Question:

Is it the intent of Section 310.1 to require an emergency escape and rescue opening in an attic used solely for incidental storage?

Answer

No, the code states habitable attics only.

The definition of habitable space in the code is: A space in a structure for living, sleeping, eating or cooking. Bathrooms, toilet compartments, closets, halls, screen enclosures, sunroom Categories I, II and III as defined in the AAMA/NPEA/NSA 2100, storage or utility space and similar areas are not considered habitable spaces.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.