



**Informal Interpretation Report
Number 7040**



Date August 03, 2012

Edition 2010

Section 1016

Question:

Assuming a USPS Mail Processing & Delivery Facility is classified as Factory Group F - Special Purpose F-3, Is it the intent of Table 1016.1, by omission, to allow an unlimited travel distance?

Answer

No. F-3 is a Florida Amendment and is normally grouped with F-2, which has a 400 foot Travel Distance if sprinklered.

Commentary:

If one Code is silent the other would prevail.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.