



**Informal Interpretation Report
Number 7047**



Date August 08, 2012

Edition 2010

Section 4101.19

Question:

Is it the intent of the Florida building code to restrict or negate industry standard installation practice for inground fiberglass pools which require equalization (filling with water) of lateral pressure for backfilling of pool. (Standard installation instructions).

Answer

R4101.19 provides an exemption for fiberglass pools.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.