



**Informal Interpretation Report
Number 7061**



Date August 14, 2012

Edition 2010

Section 443.3.5.1(Exception)

Question:

Is it the intent of this section of the code that once the unisex toilet rooms are provided for grades K-3rd, additional separate facilities for boys & girls in the same grades K-3rd are not required?

Answer

Yes.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.