



**Informal Interpretation Report
Number 7066**



Date September 27, 2012

Edition 2010

Section 606.4

Question:

Is it the intent of the code to comply with FBC Chapter 16, specifically section 1618.4 in regards to safeguards.

Answer

The reference to Chapter 16 is related to design criteria such as design pressure and opening protection outside the limits of the Exceptions. The section does not refer to Section 2411.5.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.