



**Informal Interpretation Report
Number 7067**



Date September 27, 2012

Edition 2010

Section 1604.9

Question:

Is it the intent of 1604.9 Counteracting structural actions, that a drive-up Automated Teller Machine mounted to a raised drive through island be designed to resist forces due to wind, with consideration of overturning, sliding and uplift?

Answer

Yes.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.