



**Informal Interpretation Report  
Number 7073**



**Date** September 27, 2012

**Edition** 2010

**Section** 308.4

**Question:**

Is it the intent of chapter 3, section 308.4 to require tempered glass OUTSIDE of a tub or shower in a bathroom if it is less than 60 in any direction?

**Answer**

Yes, in accordance with the Code BOOK (not the electronic version). Safety Glazing required if less than 60 inches above the walking surface and/or is within 60 inches horizontally of the water's edge.

**Commentary:**

None.

---

**Notice:**

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.