



## Informal Interpretation Report Number 7113



**Date** November 28, 2012

**Edition** 2010

**Section** 2315.1.11

### **Question:**

Is it the intent of section 2315.1.11 to require wet/dry testing for door stiles and panels made from same species solid wood boards, face and edge glued together with a urea-formaldehyde resin?

### **Answer**

No. Stiles, rails and panels shaped from solid wood are not required to undergo this testing. However, door leaf stiles, rails and panels that are made of wood-based structural panels including fiberboard, hardboard or particleboard require compliance with section 2315.1.11 of the 2010 FBC for use in the HVHZ.

### **Commentary:**

Reference to Miami-Dade County's checklist #0475 is typically made when needing to elaborate how to affect the code prescribed moisture cycling test for wood-based structural panels including fiberboard, hardboard or particleboard.

---

### **Notice:**

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.