



**Informal Interpretation Report
Number 7117**



Date December 21, 2012

Edition 2010

Section FECC 101.4.1

Question:

Is it the intent of FECC 2010, Table 101.4.1 to require a full performance method energy analysis of an addition of an air conditioning unit to a space previously unconditioned, such as a warehouse?

Answer

Yes.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.