



**Informal Interpretation Report
Number 7118**



Date December 21, 2012

Edition 2010

Section 710 Drainage System Sizin

Question:

Is it the intent of Table 710.1(1) to allow as many as nine(9) public water closets(1.6 gpf) to be connected to a 3" building drain or branch of the building drain?

Answer

Yes - there is no limit on the number of WCs on 3-inch, only 36 dfu max. The WC limitation in question went away with the 2001 edition of the Florida Building Code.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.