



**Informal Interpretation Report
Number 7141**



Date February 05, 2013

Edition 2010

Section 3002.4

Question:

Is it the intent of Section 3002.4 to exempt a 3 story, 4 unit Apartment Building from the requirement of an elevator?

Answer

No.

Commentary:

The building would be exempt from the requirements of the section cited, however, other portions of the code may require. Note the section stated in this question is directly related to the requirement for an ambulatory stretcher and this response does not apply to any other requirement for vertical accessibility. An ambulatory stretcher elevator is not required for the case cited.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.