



**Informal Interpretation Report
Number 7146**



Date February 06, 2013

Edition 2010

Section 505 and table 403.3

Question:

Is it the intent of the Florida Mechanical Code to have all residential kitchen hoods ducted to the outside, eliminating the recirculating kitchen hoods in residential apartments. There is a conflicting requirement between table 403.3 and Section 5 of the FMC.

Answer

In response to this question, Chapter 4 and Chapter 5 of the FBC-M would only apply to R-1, R-2 and R-4 occupancies. Or R-3 occupancies greater than 3 stories. Additionally, section 505 simply states, where hoods are provided. If no hood is installed, then the section 505 requirements do not apply.

Commentary:

Compliance with the ventilation requirements of Chapter 4 may also be achieved through natural ventilation found in 402. If compliance is done via 402, then the rates established in 403 are not enforced. Section 401.2 allows for compliance using either 402 or 403. If Table 403.3 of the FBC-M is used for compliance, then exhaust air from the kitchen area must be provided to the outdoors at a rate of 25 CFM per 100 sq. ft. This does not have to be done using a kitchen hood system. It may utilize other exhaust systems such as a ceiling-mounted exhaust fan with a grille ducted to the exterior of the building.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida

Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.