



**Informal Interpretation Report
Number 7158**



Date April 08, 2013

Edition 2010

Section R301.2.1.2

Question:

Is it the intent of Sec. R301.2.1.2 to exempt a conservatory addition that will not be under an existing residence roof from the protection of openings (windows) in a 140mph wind borne debris region?

Answer

No. However, the answer to the question would be yes, if the sunroom is being constructed under an existing roof.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.