



**Informal Interpretation Report  
Number 7176**



**Date** May 31, 2013

**Edition** 2010

**Section** chart 709.1

**Question:**

Is it the intent of this chart 709.1 to cover sizing of residential sanitary drainage Stack for a Clothes Washer and other sanitary issues?

**Answer**

NO. The Residential Code, Tables P3004.1 and P3201.7, define fixture unit values and trap sizes for clothes washers.

**Commentary:**

It is not permissible to reference the Plumbing Code for structures which in accordance with R101.2 fall under the scope of the Residential Code.

---

**Notice:**

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.