



**Informal Interpretation Report
Number 7192**



Date June 01, 2013

Edition 2010

Section 1604.5

Question:

Is it the intent of Table 1604.5 under Risk Category I, Screen Enclosures, to limit this to only stand alone screen enclosures that are not attached to a building structure?

Answer

No. Section 1604.5.1 states "Where buildings or structures have two or more portions that are structurally separated, each portion shall be separately classified."

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.