



**Informal Interpretation Report
Number 7210**



Date July 22, 2013

Edition 2010

Section 3006.6

Question:

Is it the intent of of this section to not allow condensate drain piping, including condensate pumps, in an elevator machine room that is removing condensate from an air conditioning unit located in the machine room that serves only the machine room?

Answer

No, a condensate would not be a plumbing system as defined by the FBC-Plumbing. Therefore, condensate piping and related pumps for equipment serving only the elevator equipment room would be allowed.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.