



**Informal Interpretation Report
Number 7225**



Date September 10, 2013

Edition 2010

Section 411

Question:

Is it the intent of the code that an amusement park having a 5000 sf bumper car attraction under roof be considered as special amusement per 411 in the Florida Building Code .

Answer

Not necessarily. If the facility meets the definition found in 411.2, then the answer is yes.

Commentary:

The key to the classification is easily and readily identifiable exits. If any system, visual and/or audible, or construction method obstructs the obvious path of exit or hinders the occupants ability to readily discern the exit way and/or exit, then you must meet the requirements of 411.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.