



**Informal Interpretation Report
Number 7241**



Date September 28, 2013

Edition 2010

Section 501.1

Question:

Is it the intent of the 2010 Existing Building Code to govern the repair of a building damaged by fire.

Answer

Yes

Commentary:

However, the design professional can choose to comply with FBC at their option.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.