



**Informal Interpretation Report
Number 7245**



Date September 28, 2013

Edition 2010

Section 411

Question:

Is it the intent of the code that a laser tag amusement attraction inside of a building be consider as special amusement.

Answer

A definitive answer could not be provided. See commentary below.

Commentary:

Would need more information on the actual layout to answer definitively. I have seen these type facilities with reduced lighting and barriers and noise that have direct exit doors around the perimeter with exit lights making the exit clearly apparent.

Unless the design clearly falls outside of the criteria contained in the definition of 411.2. The burden would

be on the design profession to show that the criteria in definition is not met for the particular design of this facility.

Note: The Life Safety Code/FFPC contains a similar provision and the annex text appears to infer that this type of facility would be included

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.