



**Informal Interpretation Report
Number 7250**



Date September 28, 2013

Edition 2010

Section 1204.1 exception

Question:

Is it the intent of 1204.1 to apply to ALL spaces.
Or can the exception be applied to spaces that ARE
NOT INTENDED for human comfort such as an
warehouse area.

Answer

NO

Commentary:

The space in question is not intended for human comfort.

Therefore, the exception to 1204.1 applies. However, the

occupancy must still comply with the Florida Building Code

Mechanical Section 401.2.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.