



**Informal Interpretation Report
Number 7258**



Date October 29, 2013

Edition 2010

Section 1018.1 & 1015.1

Question:

Does not 1018.1 exception 4 connect back 1015.1

Answer

Yes it does and if the design is allowed by 1015.1 to not

require two Exit Accesses the corridor is not required to

be protected.

Commentary:

Section 1021.2 sets the limits for single Exits from

stories and is not the test for compliance with 1018.1

exception 4.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.