



**Informal Interpretation Report
Number 7267**



Date October 20, 2013

Edition 2010

Section 1021.2

Question:

Can a "space" with 2 exit doors be designed under the more restrictive requirements of a "single exit" If so, can the 75' travel distance be measured to any of the exits, or must only (1) be designated.

Answer

NO

Commentary:

The two requirements are separate and cannot be co-mingled.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.