



**Informal Interpretation Report
Number 7295**



Date January 27, 2014

Edition 2010

Section 2002.3.3

Question:

Is it the intent of the Florida Building Code, Building, to require Florida Product Approval be demonstrated for removable panels being used in Category II and III Sunrooms?

Answer

No

Commentary:

The wind break panels are not covered by the Product Approval Rule. The question was taken to the Product Approval POC in the past and they were ruled outside the purview of the rule as they are not structural in nature.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.