



**Informal Interpretation Report
Number 7297**



Date February 04, 2014

Edition 2010

Section 907.2.1.1

Question:

Is it the intent of 907.2.1.1 that it supersede NFPA 101 12.3.4.3.3 when occupant load is less than 1000 people?

Answer

No

Commentary:

If there is a difference between two codes, the most stringent always applies.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.