



**Informal Interpretation Report
Number 7300**



Date February 04, 2014

Edition 2010

Section 909.1.1

Question:

Section 909.1.1 describe the requirements of a wet vent system. Is there any limitation on the developed length of the horizontal section of a wet vent?

Answer

NO

Commentary:

There is no limit on the length of the wet vent.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.