



**Informal Interpretation Report
Number 7302**



Date February 04, 2014

Edition 2010

Section 1014

Question:

Is it the intent of section 1014.2 to allow required means of egress to pass through different occupancy types if both under 1 tenant.

Answer

Yes, provided they are accessory to one or the other and are not considered a Group H occupancy.

Commentary:

The calculation for sizing the exits in the group F occupancy should include 1/2 the occupant load of the of the group B occupancy space.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.