



**Informal Interpretation Report
Number 7312**



Date March 03, 2014

Edition 2010

Section 504.6.4.1

Question:

Is it the intent of Section 504.6.4.1 to include the length of the transition (normally flexible) duct in the 35 foot total length.

Answer

No

Commentary:

The 35 feet starts at the point where the dryer transition duct connects to the smooth metal exhaust duct, to the outlet terminal.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.