



**Informal Interpretation Report
Number 7324**



Date April 14, 2014

Edition 2010

Section 403.1

Question:

Is it the intent of FPC403.1 to require each individual storage building on a site to meet the minimum fixture requirement?

Answer

No

Commentary:

The facilities may be in a central location, if the travel distance is within the requirements of 403.3.2 (500 ft), and the count meets the minimum of table 403.1. Directional signage would also be required per FBC Plumbing 403.4.1

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.