



**Informal Interpretation Report
Number 7369**



Date July 16, 2014

Edition 2010

Section 507.2.1

Question:

Is it the intent of 507.2.1 to require wood burning pizza ovens be installed under a Type 1 hood?

Answer

Yes

Commentary:

A Type I hood is required by code. Wood fired cooking appliances are considered extra-heavy-duty cooking appliances per definition at Section 202.1. Section 507.2.1 requires a Type I hood for extra-heavy-duty-cooking appliances. Further, Section 917.1 requires them to be listed, labeled and installed in accordance with the manufacturer's installation instructions and compliance with UL 2162

Based on the Florida Building Code - Mechanical 2010

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.