



**Informal Interpretation Report
Number 7378**



Date July 25, 2014

Edition 2010

Section 602

Question:

Can an open parking garage be constructed as a Type III-B construction

Answer

No, per FBC 2010 406.3.3 it must be Type I,II or IV construction.

Commentary:

None

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.