



**Informal Interpretation Report
Number 7381**



Date August 08, 2014

Edition 2010

Section 607.1

Question:

Is it the intent of section 607.1 to supply hot water to a service sink in a warehouse/air plane hanger for storage.

Answer

Hot water is required for a service sink

Commentary:

The code does require a service sink in storage occupancies, and it is reasonable to assume that its purpose is for cleansing or building maintenance, which requires hot water. This could be met with an inexpensive 110V tankless heater.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.