



**Informal Interpretation Report
Number 7382**



Date August 22, 2014

Edition 2010

Section 303.6

Question:

Is it the intent of the code to require illumination of a stair where the stair is to get off a deck around a mobile home.

Answer

Yes, in the vicinity of the top landing of the stairway. The deck itself could be considered the landing.

Commentary:

None

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.