



**Informal Interpretation Report
Number 7387**



Date September 02, 2014

Edition 2010

Section 107.3.

Question:

Is it the intent of Section 107.3.5 to require a duct system to be submitted on plans for residential(one and two family).

Answer

In general, no. However, the building official may require such documents where special conditions exist. e.g. a very large and complex house.

Commentary:

Be aware of local jurisdictions that require plans for these systems under a local ordinance. If this is the case, the local ordinance must be posted at www.floridabuilding.org for local technical amendments. Local technical amendments may be researched at https://floridabuilding.org/bc/bc_srch.aspx

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.