



**Informal Interpretation Report
Number 7393**



Date September 02, 2014

Edition 2010

Section 2002.4

Question:

Is it the intent of Table 2002.4 to only apply to aluminum structures that meet the strict definition of "screened enclosures" as found in Chapter 2, i.e: screened walls with a screened or other light weight roof?

Answer

No, the intent of 2002.4 is not to apply ONLY to screen enclosures with a screened or other light weight roof. The definition has been modified for the FBC 5th Edition to clarify this intent.

Commentary:

It appears an additional question is asked in the comment section. The answer to this question is yes, while the answer to the original question remains no.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.