



**Informal Interpretation Report
Number 7401**



Date September 26, 2014

Edition 2007

Section 504.4

Question:

Is it the intent of section 504.4 for all dryer ducts domestic and commercial not to penetrate plenums.

Answer

Yes

Commentary:

None

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.