



**Informal Interpretation Report
Number 7414**



Date October 21, 2014

Edition 2010

Section 1003.4

Question:

Is it the intent of section 1003.4 to require an oil and sand interceptor for a fire truck wash out station connected to the City sanitary sewer system.

Answer

This is a judgement call by the Building Official. While an interceptor may not be required for ordinary vehicle washing, if they are pressure washing undercarriages or performing vehicle maintenance, an interceptor might be called for.

Commentary:

None

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.