



**Informal Interpretation Report
Number 7437**



Date January 26, 2015

Edition 2010

Section R321

Question:

Is it the intent of ASME A17.1 to allow the elevator hoistway in a 3-story single family home, with a garage on the first level, to be conditioned by ductwork which is connected to either the house air system(s) or a dedicated system?

Answer

This is a question for the ASME, there is a interpretation process for ASME to interpret their documents.

In referencing the noted document, it does not appear to address this situation which would not prohibit it for residential.

Commentary:

None

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.