



**Informal Interpretation Report
Number 7439**



Date January 26, 2015

Edition 2010

Section 1014-1018

Question:

Is it the intent of Chapter 10 to require that all exit access hallways be defined as corridors and therefore have a rated wall and door entering the exit access component?

Answer

No

Commentary:

None

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.