



**Informal Interpretation Report
Number 7442**



Date January 28, 2015

Edition 2010

Section 307.2.2

Question:

Is it the intent of section 307.2.2 to require
condensate pvc pipe joints to meet FBC-P section
705.14

Answer

For the joints in the piping, the answer is yes. You make
a comment regarding the condensate going into a gutter.
this may may be the "approved place of disposal" addressed
in 307.2.1 which would be an indirect waste.

Commentary:

None

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.