



**Informal Interpretation Report
Number 7446**



Date February 17, 2015

Edition 2010

Section 419.4.2.5, 1609.1.2, 1626

Question:

Should FBC impact requirements apply to glazed walls as well as other adjacent non-glazed walls such as composite panels.

Answer

No, opening protection requirements apply solely to glazed openings.

Commentary:

None

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.