



**Informal Interpretation Report
Number 7515**



Date July 07, 2015

Edition 2010

Section 1003.4

Question:

Is it the intent of 1003.4 to allow a fire station apparatus garage with floor drains that do not connect to an oil/sand separator where no maintenance operations are performed within the building (all equipment is moved offsite to Public Works maintenance Garage for servicing)?

Answer

Yes.

Commentary:

None

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.