



**Informal Interpretation Report
Number 7533**



Date July 15, 2015

Edition 2014

Section R311.2

Question:

Is it the intention of code section R311.2 that egress doors may only be allowed to swing in the direction of egress travel?

Answer

No

Commentary:

R311.1 does not require egress doors to swing in the direction of travel. Florida Building Code - Building volume section 1008.1.2 should not be used for Buildings which fall under R101.2

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.