



**Informal Interpretation Report
Number 7534**



Date July 15, 2015

Edition 2010

Section 903.2.8

Question:

Is it the intent of this section to require sprinklers throughout a building protected in accordance with NFPA 13R even in areas where NFPA 13R permits sprinklers to be omitted?

Answer

No. The intent is to have the sprinkler system installed in accordance with the appropriate standard.

Commentary:

None

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.