



**Informal Interpretation Report
Number 7535**



Date August 03, 2015

Edition 2014

Section 507.16.1

Question:

Is it the intent of this section to require a capture and containment test to be performed on a Type II hood system?

Answer

Yes

Commentary:

507.16 states "the test shall verify the rate of exhaust airflow required by Section 507.13". Section 507.13 covers type I and type II hoods

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.