



**Informal Interpretation Report
Number 7594**



Date September 10, 2015

Edition 2014

Section 2709.2

Question:

Is it the intent of code section 2709.2 to require a shower lining in shower compartments where the finished shower drain is depressed a minimum of 2 inches (51 mm) below the surrounding finished floor on the first floor level and the shower recess is poured integrally with the adjoining floor?

Answer

Yes, the Exception was removed from the code. This was a Florida specific amendment that was not resubmitted for the 5th Edition.

Commentary:

None

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.