



**Informal Interpretation Report
Number 7624**



Date September 22, 2026

Edition 2014

Section 403.3.2

Question:

Is it the intent of provide dual fire tap connections to a high- rise Building. The exception to this section is the one applicable for this case because is in the beach and there is only one city water main to tap from. Does every tap connection requires independent back-flow preventer, PVI and Gate valve? or the taps can be independent sharing one same back-flow , PIV and gate valve?

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.