



**Informal Interpretation Report
Number 7633**



Date September 24, 2015

Edition 2014

Section 303.1.1 & 508.4

Question:

Is it the intent of section 303.1.1 allowing an A-2 Occupancy less than 50 to be considered a Business occupancy to allow it to be applied to table 508.4 as a Business for separation requirements?

Answer

Yes, the assembly use is classified as Group B by virtue of the occupant load.

Commentary:

None

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.